



SEE PUMP
BASE DETAIL
TYP. 3

7x7x1/4" PL
TYP. 4

GRUNDFOS
CENTRIFUGAL
PUMP
MODEL CR15-2
2" FLG DSCG
2" FLG SUC.

GRUNDFOS
CENTRIFUGAL
PUMP
MODEL CR15-2
2" FLG DSCG
2" FLG SUC.

2	2 1/2" STRAINER
1	2 1/2" GATE VALVE
PIPING SCHEDULE	

NOTES:

1. TANK TO BE 7GA CARBON STEEL
2. TANK END PLATE TO BE 1/4 PLATE CARBON STEEL
3. PAINT HI-TEMP BLACK
4. AFS LOGO BE INSTALLED ON TANK PRIOR TO SHIPMENT
5. TANK TO BE OF ALL WELDED CONSTRUCTION

AFS energy systems		PROJECT: 825 GALLON FEEDWATER TANK ASSEMBLY	
		FOR: BAILLIE LUMBER	
DATE: 6/24/04	ISSUE: 1	REV: 1	PA
DESIGNED BY: SCT	CHECKED BY:	DATE: 6/24/04	
DRAWN BY: FWB00.DWG	SCALE: 3/4"=1'	TITLE: FW TANK ASSY	